

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1496:169 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Firecom, Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100 FAX (718) 899-1932

DESIGN: Model FAS-24MCW audible/strobe, followed by any two alpha or numeric character indicating lettering and product color.

Model FASWP-2475W audible with integral private mode fire/emergency visual signaling for non-hearing impaired applications. Model FASWP-2575W is also suitable for outdoor use.

RATING: Electrical FAS-24MCW, FASWP-2475W: 16-33 VDC
Candela 15:15cd, 1575:15/75cd, 30:30cd, 75:75cd, 100:100cd, 110:110cd
FAS-24MCW: Selectable 15cd, 30cd, 75cd, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Models FASWP-2475W and FAS-24MCW are for wall mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as audible and audible/visual signaling devices suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization, Models AS Series must be used with Model SM-12/24, SMX-12/24, DSM-12/24 or DSMX-12/24 sync control module (CSFM Listing No. 7300-0785:132).

These appliances can produce a distinctive three pulse Temporal Pattern fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: Model FASWP-2475W audible device is not suitable for the hearing impaired applications.

XLF: 7125-0785:131

*Rev. 04-02-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager